

**DRAFT** 

## Bay-Delta Standards Contained in D-1641

## **DRAFT**

CRITERIA	Jul 08	Aug 08	Sep 08
FLOW/OPERATIONAL			
Fish and Wildlife			
SWP/CVP Export Limits			
Export/Inflow Ratio		65% of Delta Inflow	
Minimum Outflow - mon.	4000 cfs	3,000 cfs	3,000 cfs
- 7 day avg.	3000 cfs	2,000 cfs	2,000 cfs
Suisun Marsh			
Habitat Protection Outflow, X2			
River Flows:			
@ Rio Vista - min. mon. avg.			3,000 cfs
- 7 day average			2,000 cfs
@ Vernalis: Base -min. mon. avg.			
- 7 day average			
Delta Cross Channel Gates			
WATER QUALITY STANDARDS			
Municipal and Industrial			
All Export Locations	Cl <= 250 mg/l		
Contra Costa Canal	CI <= 150 mg/l for 155 days (178 Days have been met )		
Agriculture			
Western/Interior Delta	Max 14-dm EC ( Emmaton <=2.78 mS/cm, Jers 30-day running aver		30-day running average EC <=1.0 mS
Southern Delta	30-day rummig aver	uge 20 <= 0.7mc	or day running average EO <=1.0 m3
Fish and Wildlife     Son Longuin Biver Solinity			
San Joaquin River Salinity Suisun Marsh Salinity			
Suisuii Marsii Salifilty			


Water Year Classification: Dry (Based on 05/01/2008 forecast)

SVI (40-30-30 @ 50%) = 5.4 (CRITICAL) Apr 8RI: 1.892 MAF

SJV (60-20-20 @75%) = 2.1 (CRITICAL)

## **SWP & CVP CY 2008 Forecasted Operations**

(based on 07-01-08 water supply update)



Flows are monthly averages. O&M; cfpl072308.xls